

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME**

CB TEST CERTIFICATE

Product

DC Power Supply

Name and address of the applicant

NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095
JAPAN

Name and address of the manufacturer

NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095
JAPAN

Name and address of the factory

NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095
JAPAN

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Page 2

Trademark / Brand (if any)

None

Type of Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PCFX-220Px
(where x maybe maximum 50 characters, any alphanumeric character, hyphen or blank, which denotes control number)

Additional information (if necessary may also be reported on page 2)

Additionally evaluated to EN 62368-1:2014/ A11:2017.
National Differences specified in the CB Test Report.

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

E161936-A6015-CB-1 issued on 2020-05-26

This CB Test Certificate is issued by the National Certification Body



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2020-05-27

Signature:



Masamichi Takagi

Factories:

NIPRON CO LTD

3249 OIZU INDUSTRIAL PARK IN OYODO KOGYO DANCHI OAZA-YAMAOIZU AZA-NAKAJIMA MEIWA-CHO

TAKI-GUN MIE-KEN 515-0303

JAPAN

Ratings:

Input:

100V-240V~, 50/60Hz, 2.5A-1.1A

Output:

CH1: +5 Vdc, 10A (peak 12A)

CH2: +3.3 Vdc, 10A (peak 12A)

CH3: +12 Vdc, 10A (peak 12A)

CH4: -12 Vdc, 0.3A

CH5: +5VSB, 2A

Peak: Maximum 5 seconds

Interval: 45 seconds

Total Wattage: Maximum 170 W

Total Peak Wattage: Maximum 220 W

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/nbcnames

Date: 2020-05-27

Signature:

Masamichi Takagi

