



Ref. Certif. No.

JP-26304-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product Switching Power Supply

Name and address of the applicant NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095 JAPAN

Name and address of the manufacturer NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095 JAPAN

Name and address of the factory NIPRON CO LTD
2-57 OHAMA-CHO AMAGASAKI-SHI HYOGO-KEN 660-0095 JAPAN

Note: When more than one factory, please report on page 2

Ratings and principal characteristics See Page 2

Trademark (if any) Nipron

Customer's Testing Facility (CTF) Stage used

Model / Type Ref. GPSA-5000-48Px, GPSA-5000-96Px
(where x may be maximum 20 characters, any alphanumeric character, slash, hyphen or blank, which denotes control number)

Additional information (if necessary may also be reported on page 2) The report was revised to include technical modifications. Additionally evaluated to EN 62368-1:2014/ A11:2017. National Differences specified in the CB Test Report.

A sample of the product was tested and found to be in conformity with ☒ Additional Information on page 2
IEC 62368-1:2014

As shown in the Test Report Ref. No. which forms part of this Certificate E161936-A6050-CB-1 issued on 2022-07-20

This CB Test Certificate is issued by the National Certification Body



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☐ UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☒ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-07-21
Original Issue Date: 2022-07-13

Signature: 
Masamichi Takagi



Ref. Certif. No.

JP-26304-M1-UL

Factory(ies):

NIPRON CO LTD
3249 OIZU INDUSTRIAL PARK IN OYODO KOGYO DANCHI OAZA-YAMAOIZU AZA-NAKAJIMA MEIWA-CHO TAKI-GUN
MIE-KEN 515-0303
JAPAN

Ratings:

Model GPSA-5000-48Px:
Input: 200-240V~, 50/60Hz, 15.5-13A, 3phase
Output: 48Vdc/100A, 12VSB/0.5A

Model GPSA-5000-96Px:
Input: 200-240V~, 50/60Hz, 18-15A, 3phase
Output: 96Vdc/60A, 12VSB/0.5A

or

Input: 200-240V~, 50/60Hz, 15.9-13.4A, 3phase
Output: 96Vdc/52A, 12VSB/0.5A

Summary of Modifications:

- Addition of Model GPSA-5000-48Px.

Additional information (if necessary)



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☐ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☒ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-07-21
Original Issue Date: 2022-07-13

Signature:

M. Takagi
Masamichi Takagi